

Raychem Energy Division

Report





Title		Pages:
QUALIFICATION OF ADHESIVE COATED WCSF-N HEAT SHRINKABLE TUBING TO ANSI G119.1-1974		9
		Enclosures:
Report Number:	Date:	Revision 1
EDR 5008	March 18, 1980	
Tested by:	Signature:	Date:
Eusebio F. Menezes		March 19, 1980
Prepared by:	Signature:	Date:
Eusebio F. Menezes		March 19, 1980
Approved by:	Signature:	Date:
Graham J. Clarke for Technical Operations		4/23/80.
Approved by:	Signature:	Date:
Robert Scott for Product Management Raychem Corporation Energy Division		4/21/80

TABLE I
SUMMARY OF TEST RESULTS

TESTS	TEST REQUIREMENTS	GROUP I			GROUP II		
		TEST SEQUENCE	TYPICAL VALUES	TEST SEQUENCE	TYPICAL VALUES		
1. Water Immersion	Samples under 12-inch head of water at $23^{\circ}\text{C} \pm 3^{\circ}\text{C}$ for 24 hours		Passed		Passed		
2. Insulation Resistance	Greater than 2.5×10^6 ohms measured at 500V d.c.		$> 10^{10}$ ohms		$> 10^{10}$ ohms		
3. Dielectric Withstand	2.2kV a.c. 60 hertz for 1 minute		Passed		Passed		
4. Heat Conditioning	72 hours at $90^{\circ}\text{C} \pm 5^{\circ}\text{C}$ or 192 hours at $80^{\circ}\text{C} \pm 5^{\circ}\text{C}$		Passed		Passed		
5. Flexing Test	Ten flex cycles through an arc of 180°		Passed		Passed		
6. Twist Test	Five longitudinal axis twists through an arc of 30°		Passed		Passed		
7. Cold Temperature Test	Four hours at -23°C		Passed		Passed		
8. Cold Flexing Test	Similar to (5) with samples at -23°C		Passed		Passed		
9. Cold Twist Test	Similar to (6) with samples at -23°C		Passed		Passed		
10. Water Immersion (loop)	Samples under 12-inch head of water at $23^{\circ}\text{C} \pm 3^{\circ}\text{C}$ for 24 hours		Passed		Passed		
11. Insulation Resistance (loop)	Greater than 2.5×10^6 ohms measured at 500V d.c.		$> 10^9$ ohms		$> 10^9$ ohms		
12. Current Cycle/Water Immersion	Conductor current cycled to 90°C within 1-hour followed by water immersion of samples for 30 minutes, 50 cycles		Passed		Passed		
13. Leakage Current	Leakage current less than 2.5mA at 600V a.c. 60 hertz.		70 μ amps		70 μ amps		
14. Voltage Breakdown (optional)	Increase voltage at 500V a.c./sec. until failure		$> 26\text{kV}$		$> 26\text{kV}$		

OBJECTIVE

To demonstrate the performance of Raychem's low voltage in-line field splice system (type WCSF-N). Testing was conducted in accordance with American National Standard Institute, ANSI C119.1, 1974 "Sealed Insulated Underground Connector System Rated 600 Volts".

SUMMARY

A total of 75 in-line splices were evaluated. The first set of test samples were tested on the extremes of the conductor size the splice was capable of accommodating (Items 1, 2, 8 to 11, Table II) to verify performance at the design limits. Cable conductor sizes #8 AWG through 1000 MCM were used.

The second set of test samples (Items 3 to 7, Table II) were chosen to evaluate the sealing performance of the splices to the different cable type substrates.

All test samples passed the specific and design criterion. The results are summarized in Table I.

CONCLUSION

The test program results indicate that the splices exceeded the ANSI electrical requirements after the sequential testing. The product is qualified as an environmentally sealed insulation system for low voltage power applications.

SAMPLE PREPARATION

Samples consisted of crimped splices insulated with WCSF flame-retarded tubing coated with type S-1119 adhesive. Cable lengths two feet long were spliced together in accordance with standard installation instructions. The test sample matrix used in the evaluation is given in Table II

TABLE II
GROUP I SAMPLE MATRIX

Item	No. of Samples	Product	Cond. Size	Cable Type	
				Insulation Type	Voltage
1	3	WCSF-200-6-N	#8 AWG	XLPE Type XHHW	600V
2	3	WCSF-200-6-N	#4 AWG	XLPE Type XHHW	600V
3	3	WCSF-300-6-N	#2 AWG	XLPE Type XHHW	600V
4	3	WCSF-300-6-N	#2 AWG	EP Type RHH or RHW	600V
5	3	WCSF-300-6-N	#2 AWG	PVC Type THW Oil Resistant	600V
6	3	WCSF-300-6-N	#2 AWG	HM Black Polyethylene	600V
7	3	WCSF-300-6-N	#2 AWG	Neoprene Jacketed Cable	600V
8	3	WCSF-500-6-N	4/0 AWG	XLPE Type XHHW	600V
9	3	WCSF-500-6-N	250 MCM	EP type RHW	600V
10	3	WCSF-1000-12-N	750 MCM	XLPE Type XHHW	600V
11	3	WCSF-1000-12-N	1000MCM	XLPE Type XHHW	600V

TESTING

The qualification test program consisting of a sixteen step sequence as detailed in Section 3.3, "Seal Test Procedures" of ANSI C119.1, 1974 was implemented as follows:

TESTING (Cont'd)

Step 1 All spliced samples were immersed under a 12-inch head of tap water at $23^{\circ}\text{C} \pm 3^{\circ}\text{C}$ for 24 hours.

Step 2 Insulation resistance measurements were taken on the immersed samples between conductor and the grounded water bath using a megohmmeter set at 500V d.c.

Result: Nominal value of 33 samples: 3.0×10^{11} ohms
Minimum value of 33 samples: 6.0×10^{10} ohms

Step 3 Dielectric withstand tests were performed at 2.2kV a.c. 60 hertz applied between conductor and the grounded water bath.

Result: All samples passed.

Step 4 Samples were heat conditioned in an air circulating oven for 72 hours at $90^{\circ}\text{C} \pm 5^{\circ}\text{C}$.

Step 5 After cooling down to room temperature, the samples were subjected to flex cycles through an arc of 180° .

Result: The 750 MCM and 1000 MCM cable size samples were not tested. It was difficult to manually flex the cable. All other samples underwent this test with no visible damage observed.

TESTING (Cont'd)

Step 6 All samples were twisted around the longitudinal axis of the splice through an arc of 30°.

Step 7 Samples were then water immersed as described in Step 1.

Step 8 Insulation resistance measurements were taken as described in Step 2.

Results: Nominal value of 33 samples: 1.0×10^{11} ohms
Minimum value of 33 samples: 1.0×10^{10} ohms

Step 9 The samples were placed in a circulating air refrigeration chamber and cooled to -23°C for a period of 4 hours.

Step 10 While at -23°C, the samples were flexed as described in Step 5.

Result: The 750 and 1000 MCM size cable splices were not tested due to difficulty of flexing these sized cables.

A PVC insulated cable and a HM black polyethylene insulated cable cracked during flexing. The cables were repaired by shrinking coated WCSF tubing over the cracked area. All other samples passed the test with no visible damage observed.

TESTING (Cont'd)

Step 11 While at -23°C, the samples were twisted around the longitudinal axis of the splice through an arc of 30°.

Step 12 Samples were water immersed as described in Step 1.

Step 13 Insulation resistance measurements were taken as described in Step 2.

Result: Nominal value of 33 samples: 7.0×10^{10} ohms.
Minimum value of 33 samples: 1.0×10^{10} ohms.

Step 14 A maximum of six conditioned splices of same conductor size were connected to form a loop. This splicing generated a second group of splices, Table III, which were subjected to the current cycling test sequence only.

Each loop was subjected to 50 cycles consisting of one hour heating in air by current induction through the conductor followed by immersion under two feet of $23^{\circ}\text{C} \pm 3^{\circ}\text{C}$ water for one-half hour. Insulation resistance of the loop was taken on completion of the 25th and 50th cycle.

The minimum value of insulation resistance of the loop was 3.0×10^9 ohms.

The XLPE and EPR insulation type cables were tested to $90^{\circ}\text{C} \pm 5^{\circ}\text{C}$ Conductor temperature. The PVC, HMPE and neoprene insulation type cables were tested to $75^{\circ}\text{C} \pm 5^{\circ}\text{C}$ as rated by the cable manufacturers.

TESTING (Cont'd)

At the conclusion of the current cycling tests, the splices were separated and insulation resistance measured. The 75 samples had insulation measurements of greater than 6.0×10^9 ohms which far exceeded the test requirement of 2.5×10^6 ohms.

Step 15 Dielectric withstand tests were performed as described in Step 3.

Result: All samples passed.

Step 16 Leakage current readings were obtained for each sample at 600V a.c. 50 hertz between the conductor and the grounded water bath.

Result: Nominal values of 75 samples: 70 microamps
Lowest value: 30 microamps (#8 AWG)
Highest value: 250 microamps (1000 MCM)

To provide additional dielectric strength data beyond the scope of the specification, all samples were subjected to an a.c. voltage breakdown. Breakdown values greater than 26kv were observed.

TABLE III
GROUP II - SAMPLE MATRIX (STEP 14)

Test Loop	Number of Splices		Product	Cable Type	
	Conditioned	Non-Conditioned*		Conductor Size	Insulation
1	3	4	WCSF-200-6-N	#8 AWG	600V XLPE
2	3	4	WCSF-200-6-N	#4 AWG	600V XLPE
3	6	7	WCSF-300-6-N	#2 AWG	600V XLPE and EPR
4	6	7	WCSF-300-6-N	#2 AWG	600V HMPE and PVC
5	3	4	WCSF-300-6-N	#2 AWG	600V Neoprene
6	3	4	WCSF-500-6-N	#4/0 AWG	600V XLPE
7	3	4	WCSF-500-6-N	250 MCM	600V EPR
8	3	4	WCSF-1000-12-N	750 MCM	600V XLPE
9	3	4	WCSF-1000-12-N	1000 MCM	600V XLPE

*Non-Conditioned splices are those used to connect the individually conditioned samples into a test loop.

DATA ACQUISITION INSTRUMENTS

1. Instrument No. 6571
Inst. and Mfr.: GR 1864 Megohmmeter Type No. 1864
Range/Features: 100k - 50T ohms
Date Calibrated: 8-1-78

2. Instrument No. 227
Inst. and Mfr.: AR Hypot
Type No. 4030
Range/Features: 0-4 Kilovolts, 0-5 milliamps
Date Calibrated: 8-1-78

3. Instrument No. 16813-1
Inst. and Mfr.: Sub-Zero Test Apparatus, Amer. Instrument Co.
Type No.: -
Range/Features: -150°C to +100°C
Date Calibrated: 6-20-78

4. Instrument No. 05075-014
Inst. and Mfr.: Amprobe Meter
Type: RS-1000
Range/Features: 0-1k amps
Date Calibrated: 1-19-78

5. Instrument No. 3112
Inst. and Mfr.: Digimite
Type No. 31160
Range/Features: 0-740°C
Date Calibrated: 8-1-78

6. Instrument No. 23074
Inst. and Mfr.: Hypotronics AC Corona Test Set
Type No. 7100-20CT
Range/Features: 0-100kV
Date Calibrated: 6-6-78

